

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20214290
Address: 1399 NE DOUGLAS ST, LEES SUMMIT, MO 64086
Inspected On: Monday, August 01, 2022
Inspected By: Robb Popp
Expiration Date: 8/31/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Temporary C of O	Monday, August 01, 2022

Corrective Action Required:

1	Misc	OK FOR TCO
---	------	------------

Other items that need to be addressed are the Following:

Remove porta jon.

Seal exterior penetration at east side

Verify parking lot lighting is compliant and working.

Drive thru window has plywood over it.

Open hole for vacuum vent.

Contact our Planning dept, for screening of RTU and plumbing on roof.

Address property maintenance of the parking lot.