

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215701
Address: 2107 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Tuesday, August 02, 2022

Corrective Action Required:

1	Miscellaneous Correction	Obtain irrigation permit and provide back flow certification Provide gutters and down spouts Splash blocks Sump discharge minimum of 36" from foundation Uncover smoke detectors Provide proper electrical whip for garage disposal Attach electrical whip at water heater correctly Improve water deflection shield above sub panel
---	--------------------------	---

Comments: