



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20110203, Building Permit - Commercial  
Address: 1469 SW MARKET ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Mark Harding	Partial	Monday, March 21, 2011

Corrective Action Required  
1 MISC

WALLS APPROVED TO COVER-HARD CEILING APPROVED TO COVER.

GAS TEST MAYBE REQUIRED IF GAS PIPING IS EXTENDED IN KITCHEN.

<b>Above Ceiling Inspection</b>	Mark Harding	Partial	Monday, March 21, 2011
---------------------------------	--------------	---------	------------------------

Corrective Action Required  
1 MISC

PARTIAL - HARD CEILING OVER COOLER APPROVED

ABOVE CEILING INSPECTION REQUIRED IN KITCHEN BEFORE NEW SECTION OF TILE IS INSTALLED.  
(EXISTING CEILING IN PLACE THROUGHOUT)

<b>Rough Electrical Inspection - Commercial</b>	Mark Harding	Passed	Monday, March 21, 2011
---	--------------	--------	------------------------

**Comments:**