

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212317
Address: 2113 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Monday, July 25, 2022

Corrective Action Required:

1	Miscellaneous Correction	- At beam to post connections on deck 2 @ 1/2" through bolts required on each post . no complete Shawn Hoffman 07/25/2022 8:27 AM
---	--------------------------	---

Comments: