

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215592  
Address: 2035 SW FARM FIELD LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Wednesday, August 03, 2022

Corrective Action Required:

1 Misc

- address pending driveway and sidewalk inspection
- final grade and sod
- splash blocks and sump pump discharge to extend 36" from foundation
- check water meter at time of final grade and sod
- illuminate address
- complete rear patio stairs
- guard rail at back patio where required by code
- Ladders for egress window wells
- tamper caps at A/c unit
- rock under furr outs in garage

**Comments:**