

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20216411
Address: 710 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|-----------------------|
| Underslab Plumbing Inspection - Commercial | Robb Popp | Partial | Friday, July 08, 2022 |

Corrective Action Required:

| | | |
|---|--|--------------------------------------|
| 1 | THE FOLLOWING AREAS ARE APPROVED | DWV AT 114,103,107,109, 100, 112,113 |
|---|--|--------------------------------------|

Corrective Action Required:

| | | |
|---|-----------------------------|---|
| 2 | Miscellaneous Correction | -PROVIDE CLEAN OUT AT EAST EXTERIOR CHANGE OF DIRECTION |
|---|-----------------------------|---|

Comments: