CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215300

Address: 500 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - John Jackson Passed Thursday, August 04,

Engineering 2022

Informational:

1 Misc TCO is Given

Punch list for Final Occupancy

1. Vegetation of 70%

2. Clean up all trash and debris

3. Make sure curb inlets and clean and no debris inside.

Informational:

2 Misc Final Occupancy can be give on our end.

Comments: