

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212098
Address: 1709 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Final - Residential	Mitchell Schwarz	Failed	Thursday, August 04, 2022

Corrective Action Required:

1	Misc	-Gate needs to be self closing and latching -Paint gas line with corrosion resistant paint -Label panel and breakers
---	------	--

Comments: