

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213807
Address: 2101 SW RUTHERFORD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, August 04, 2022

Corrective Action Required:

1	Misc	-resolve outstanding inspection fee -final grade and sod -splash blocks -install hardware and toe lock at sliding glass door -install attic access cover -install service panel cover -install all breakers, unable to verify electrical -install electrical at hot water heater -uncover water meter lid
---	------	---

Comments: