

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20223080  
**Address:** 4408 SW GRINDSTONE CIR, LEES SUMMIT, MO 64082

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Patrick Schonfeldt	Failed - Stop Work	Friday, August 05, 2022

Corrective Action Required  
1 Misc

INSPECTION DENIED

- FOOTING POURED WITHOUT INSPECTION, ENGINEER REPORT  
REQUIRED TO BE UPLOADED TO PORTAL WITHIN 48 HOURS OF  
INSPECTION

- ADDRESS EROSION CONTROL ON LOT

- POST SITE ADDRESS

-BACKFILL AT FOUNDATION TO ALLOW FOR COMPLETE  
INSPECTION

**Comments:**