

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214744
Address: 2119 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, August 05, 2022

Corrective Action Required:

1	Miscellaneous Correction	Anchor bolts middle third of plate at garage Not able to see PFH portal frame nail pattern, open wrap Address over notched hip landing on single garage door Provide purlin struts 4' on center Fire block top of Bvent fur out Open deck lid for inspection Protect pex basement bathroom 3" vent ductwork not allowed, replace with 4" Security blocking 3 stud bays out
---	-----------------------------	--

Comments: