

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220521  
Address: 3216 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:       | Outcome: | Date:                   |
|-------------------------------------------|------------------|----------|-------------------------|
| <b>All Rough Inspection - Residential</b> | Mitchell Schwarz | Failed   | Friday, August 05, 2022 |

Corrective Action Required:  
1      Misc      inspection denied no address posted

**Comments:**