

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20216421  
Address: 3124 SW ARBORTREE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                          | Inspector:       | Outcome: | Date:                   |
|--------------------------------------|------------------|----------|-------------------------|
| <b>Electrical Service Inspection</b> | Mitchell Schwarz | Failed   | Friday, August 05, 2022 |

Corrective Action Required:

|   |      |                                                                                                                                                                                                                                                            |
|---|------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | E3607.5<br>SYSTEM GROUNDING. An unspliced main bonding jumper shall be used to connect the equipment grounding conductor(s) and the service-disconnect enclosure to the grounded conductor of the system within the enclosure for each service disconnect. |
|---|------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

-Provide jumper from ground bar to neutral bar or land CEE on neutral bar

Corrective Action Required:

|   |      |                                     |
|---|------|-------------------------------------|
| 2 | Misc | inspection denied no address posted |
|---|------|-------------------------------------|

**Comments:**