

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220752

Address: 1980 SE BLUE PKWY, Unit:2302, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Friday, August 05, 2022

Corrective Action Required:

1 Miscellaneous
Correction

APPROVED EXCEPT AS NOTED:

-REMOVE TEMP LIGHTING, SEAL CONDUIT PENETRATION AND SUPPORT LOW
VOLTAGE IN BATHROOM AND PREP ROOM
*OK FOR BORDERS

Corrective Action Required:

2 Misc

Comments: