

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213954

Address: 2015 SW OSAGE DR, LEES SUMMIT, MO 640822017 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, August 05, 2022

Corrective Action Required:

1	Misc	unit 2017 -provide gravel base at water meter pit -uncover man hole lid -provide as graded plot plan -tamper resistant caps at A/c unit -approved access panel for ufer ground connection in garage -deck stairs greater than 7 3/4" -deck stairs rise greater than 3/8" difference
---	------	--

UNIT 2015 OK

Comments: