

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215093
Address: 1533 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, August 08, 2022

Corrective Action Required:

1	Misc	-covered patio provide joist hangers for rafters to ledger and H2.5 clips at lvl bearing -address holes drilled in floor joist above great room for pex closer than 2" to one another (submit engineer letter on field fix) -address holes drilled for pex in floor joist above foyer and office closer than 2" from one another (submit engineer letter for field fix) -seal top and bottom plate electrical penetration to on master bed -properly support and connect HVAC duct work in basement
---	------	---

Comments: