

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220195
Address: 3246 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, August 03, 2022

Corrective Action Required:

1 Misc

- cs-pf bed 1 missing straps
- uncover covered patio for inspection (secure all trussed per manufacture specs) hold downs not installed properly
- provide attic access above bed 2(protect NM With in 6' of this access)

Comments: