

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215284

Address: 3639 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643639 NE AKIN DR, Unit:C, LEES SUMMIT, MO 640643639 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643639 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Failed	Monday, August 08, 2022

Informational:

1	Misc	Attic separation-2nd layer ok
---	------	-------------------------------

1st layers unit side: seal penetrations at lbeam on 1st floors. each unit.

Comments: