

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220470
Address: 3221 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, August 08, 2022

Corrective Action Required:

2	Misc	-protect NM with in 6' of attic access -fireblock through out -solid block plate breaks in garage -provide truss plans for inspection -tie front entry wall to other exterior walls -support ridge beam at front stoop
---	------	---

Comments: