

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215490  
Address: 2812 SW HEARTHSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Monday, August 08, 2022

Corrective Action Required:

2	Misc	-final grade and sod -submit as graded plot plan to reflect current grading and pool -address pool being built without permit -splash blocks and sump pump discharge to extend 36" from foundation -obtain lawn irrigation permit -pay all fees -check water meter at time of final grade and sod -address pending driveway inspection -address piers poured without inspection -do not occupy -do not furnish
---	------	--

**Comments:**