

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212194
Address: 4721 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Tuesday, August 09, 2022

Corrective Action Required:

1	Miscellaneous Correction	<ul style="list-style-type: none">- install sidewalk and obtain approval.- sod, erosion control, splash blocks, sump discharge.-Gravel inside of water meter pit.-provide address.- seal garage attic access, provide full cover.-2nd lock on sliding door.
---	--------------------------	--

Comments: