

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221791
Address: 4717 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, August 09, 2022

Corrective Action Required:

1	Miscellaneous Correction	provide city stamped plans Post address Address Notched joist at hip in garage nail 2x4" to LVL 2 rows at 3" on center of #16 sinkers PFH portal frame Add king stud I beam garage fire block master closet at switches wiring top Install windows and nail siding through out Complete electrical at fire place wall Complete basement bathroom vent Fire block basement bathroom ceiling Fire block top of chase basement tub Fire block RA space at basement plumbing vanity Solid block over beam basement egress window
---	--------------------------	--

Comments: