



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110060, Building Permit - Commercial
Address: 970 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Failed	Thursday, March 24, 2011

Corrective Action Required

- | | | |
|---|------|--|
| 1 | MISC | WITHIN THE WIDTH OF WALL OPENINGS SCREW ALL FLANGES AT CONNECTIONS OF LIGHT-GUAGE STEEL FRAMING -- FULL HEIGHT |
| 2 | MISC | PROVIDE BACK-UP FOR ELECTRICAL BOXES WHERE STAND-OFFS ARE TOO SHORT OR NOT PRESENT |
| 3 | MISC | ENSURE COPPER PIPING IS ISOLATED FROM ANY STEEL MATERIALS |
| 4 | MISC | CLOSE ANY UNUSED OPENINGS IN ELECTRICAL BOXES |

Comments: