

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213952
Address: 3100 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, August 09, 2022

Corrective Action Required:

1	Misc	-address pending driveway and sidewalk inspections -address piers for deck poured without inspection -address pending sewer inspection -through bolts at deck post to beam connections -lock out for water heater breaker -paint gas line -tamper caps at A/c unit -seal all exterior penetrations -sod -splash blocks and sump pump discharge to extend 36" from foundation
---	------	---

Comments: