

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191206
Address: 1717 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, August 09, 2022

Corrective Action Required:

1	Misc	-GRASPABLE HANDRAIL GARAGE STAIRS PER CODE IRC R311.7.8.5 -COMPLETE DECK STAIRS, GUARDRAIL, AND HANDRAIL
---	------	---

Comments: