

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214080

Address: 2005 SW OSAGE DR, LEES SUMMIT, MO 64082 2003 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Mitchell Schwarz	Not Ready	Wednesday, August 10, 2022

Corrective Action Required:

1	Misc	(3) OF (4) PIERS APPROVED
---	------	---------------------------

**** (1) PIER ON UNIT 2005 NOT COMPLETED TO DEPTH AT TIME OF INSPECTION ****

Corrective Action Required:

2	Misc	pier indicated poured without inspection. Mitchell Schwarz 08/10/2022 8:05 AM
---	------	--

Comments: