

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220891

Address: 1014 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811016 NW BLACK TWIG CIR, LEES SUMMIT,
MO 640811018 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811012 NW BLACK TWIG
CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Mark Harding	Passed	Wednesday, August 10, 2022

Comments: