

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221415
Address: 2030 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------------|------------------|----------|----------------------------|
| All Rough Inspection - Residential | Mitchell Schwarz | Failed | Wednesday, August 10, 2022 |

Corrective Action Required:

| | | |
|---|------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | -missing top plate at garage portal frame under header nail top plate to header per plans and design NOT FRAMED CORRECTLY -strap top plate where plate breaks less than 24" W garage wall -fire block top of furr out wall in bed 3 SEAL GAPS -(2) 1/2" through bolts at each deck post to beam connection -address hips/valley rafters over notched at top plate |
|---|------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

Comments: