

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220089  
Address: 4417 SW GRINDSTONE CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Shawn Hoffman	Passed	Wednesday, August 10, 2022

Informational:  
1 Misc -Ampacity adjustment for SE cables installed in attic space is required. Refer to NEC 334/338, 310.15(B)(7)

80 Amp breaker to sub panel installed at time of inspection.

**Comments:**