

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212684
Address: 3206 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Wednesday, August 10, 2022

Corrective Action Required:

1	Miscellaneous Correction	pay fee's Final grading and sod Obtain irrigation permit and submit back flow Handrail at 4 side fron patio Secondary lock on front door Post address in contrasting colors and illuminated Spark rings needed at kitchen counter outlets Complete handrail on stairs to loft Complete hardware on garage and side entry One outlet in pantry not tripping gfci Outlets and covers in kitchen incomplete Handrail basement stairs unfinished Range vent
---	--------------------------	---

Comments: