

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20211976  
Address: 811 NE LAKEWOOD BLVD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mark Harding	Failed	Wednesday, August 10, 2022

Corrective Action Required:

1 Misc

Framing was approved for the 2hr wall.

EXTERIOR-

1st layer exterior failed: no screws in the bottom tract and studs.

INTERIOR:

1st Layer: failed - wall needs to be removed on the interior to achieve the proper screw pattern and inspection.  
sheetrock was installed with no screw pattern.

Comments: