CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20213582

Address: 3109 SW ARBORTREE DR, LEES SUMMIT, MO 64082

Inspected On: Wednesday, August 10, 2022

Inspected By: Mitchell Schwarz

Expiration Date: 9/5/2022

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Mitchell Schwarz Temporary C of O Wednesday, August

Codes Residential 10, 2022

Corrective Action Required:

1 Misc TCO UNTIL 9/5/22

-submit as graded plot plan

-sod

-splash blocks and sump pump discharge to extend 36" from

foundation

-check water meter at time of sod