

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216532  
Address: 1812 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Diana Johnson	Passed	Wednesday, August 10, 2022

Informational:

1	Misc	8.1.2022 I performed a sidewalk inspection and pass the subgrade to pour concrete
		8.10.2022 Sidewalk appears to be compliant

**Comments:**