

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20200866

Address:

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Site Visit</b>	Steve Robbins	Partial	Tuesday, August 09, 2022

Informational:

1 Misc

Water dept. noticed that Summit View trl. did not have water in the line when they did a tap. Redford retested the line and we have put one passing sample into documents and images. I have sent the sample over to water dept. and we will go out and make sure all the valves are on again tomorrow morning. Steve Robbins 08/09/2022 3:21 PM

**Comments:**