

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215273

Address: 3691 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643691 NE AKIN DR, Unit:C, LEES SUMMIT, MO
640643691 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643691 NE AKIN DR, Unit:A, LEES
SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------|----------|---------------------------|
| All Rough Inspection - Commercial | Khanh Nguyen | Failed | Thursday, August 11, 2022 |

Corrective Action Required:

1 Misc

UNIT A:

-Nail all holes of corner truss hangers above master bathroom **no access

UNIT B:

-Plumbing vent cannot be located within 4 ft of firewall **repair plywood..

-Replace gas test pressure gauge. Needle not moving when pressure is released **no access

UNIT C:

UNIT D:

Comments: