

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20214955  
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Shawn Hoffman	Failed	Thursday, August 11, 2022

Corrective Action Required:

1	Misc	Inspection on HT101A, HT202 AND HT203 ONLY
		<ul style="list-style-type: none"><li>- fire stop all penetrations in welding room</li><li>- Upload information on the fire proofing on trusses in welding room</li><li>- Provide engineers letter on ventilation for welding room.</li></ul>

OK to put in furniture in class rooms: HT101A, HT202, HT203

**Comments:**