

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220353
Address: 3113 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Thursday, August 11, 2022

Corrective Action Required:

1	Misc	No further inspections until erosion control in compliance -fire block into garage furr down see furr outs -address front entry 2nd level frame to detail -seal gap in fireblocking above 2nd floor fireplace -protect NM within 6' of attic access 2nd floor -provide minimum 10psi at gas pressure gauge for inspection
---	------	--

Corrective Action Required:

2	Misc	inspection denied erosion control not in compliance Mitchell Schwarz 08/10/2022 8:40 AM still not in compliance. Mitchell Schwarz 08/11/2022 2:16 PM
---	------	---

Comments: