CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213323

Address: 3813 SW WALSH DR, LEES SUMMIT, MO 640823811 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Shawn Hoffman Failed Thursday, August 11,

Residential 2022

Corrective Action Required:

1 Misc

-connect sewer tracer wire to box at grade

UNIT 3813:

-correct grade south side, negative slope towards foundation , $\,$ fix sod and $\,$

grade with holes and negative fall toward house.

Comments: