CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20220445

Address: 900 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

		•	, , ,	
Inspection:		Inspector:	Outcome:	Date:
Water Service Inspection		Eric Sharp	Partial	Thursday, August 11, 2022
Informational:				
1	Misc	Rudy's crew began installation of meter pits on 5/10/22. Running copper under road and coming off backside of meters ~10' with copper. 5/10/22 ES		
Informational:				
2	Misc	Rudy's crew continued installation of meter pits. Running copper under road and coming off backside of meters ~10' with copper. 5/11/22 ES		
Informational:		_	•	
3	Misc	Rudy's crew completed installation of remaining meters. Running copper off back side of main and connecting with compression fittings supplied by water utilities. 5/16/22 ES		
			on digging out water trench eters to residence. 6/6/22 I	•
		Miller plumbing working of in inspections for the mor	on water services on two la rning. 7/11/22 ES	rger buildings. Will call

Informational:

4 Misc Spoke with Rudy, as they have started performing installs on the building

due to damage. 7/11/22 ES

Walked all meter service locations with AN/RH and recorded numbers and conditions. There are multiple pits that will need to be repaired/replaced

service side any meters without 10' of copper out the back side need to be replaced and a 10' piece will need to come off the back side for the site plumbers to connect their poly to to run into building. 7/14/22 ES

Miller plumbing working on service tie ins to buildings. Copper out of meter pits is shorter than 10' and ESS will need to come replace copper from back side of meet and extend at least 10' out of meter pits. 8/10/22 ES

Miller working on service connections on town homes. 8/11/22 ES

Comments: