

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216204
Address: 1932 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Diana Johnson	Passed	Friday, August 12, 2022

Informational:
1 Misc 8.9.2022 I performed a driveway inspection and pass the subgrade to pour concrete

8.12.2022 Driveway appears to be compliant

Comments: