

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20220046  
Address: 2026 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Friday, August 12, 2022

Corrective Action Required:  
2 Misc

- seal top plate penetration N double car garage wall
- plans call for 2 2x10 above double car garage
- address dryer vent length
- address rafters to lvl connection above great room, hangers installed to high missing nails
- uncover covered patio for inspection
- seal bottom plate penetration left of windows
- seal bottom plate penetrations right of fireplace
- address over notched lvls above master
- seal top plate penetration master W wall
- seal top plate penetration above master shower
- seal top plate penetration bed 2 closet
- address holes above bar area in floor joist drilled too close together
- seal top plate penetration above basement bath sink
- fire block furr out wall to ceiling space in basement W wall and N bar wall
- fire block stairwell to basement bath furr down

**Comments:**