

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215762
Address: 504 SE DAVID RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ryan Heckman	Failed	Friday, August 12, 2022

Informational:
1 Misc 8-8-22 RH. Driveway was formed up and aggregate placed and compacted.

8-12-22 RH. Driveway was poured and covered the sanitary sewer MH 58-064.
This will need to be located and uncovered.

Comments: