

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223080
Address: 4408 SW GRINDSTONE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Shawn Hoffman	Passed	Friday, August 12, 2022

Corrective Action Required:

1	Misc	INSPECTION DENIED
		- FOOTING POURED WITHOUT INSPECTION
		- ADDRESS EROSION CONTROL ON LOT
		- POST SITE ADDRESS
		-BACKFILL AT FOUNDATION TO ALLOW FOR COMPLETE INSPECTION

Comments: