

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20213681  
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Partial	Friday, August 12, 2022

Corrective Action Required:

1	FIRST FLOOR	THE FOLLOWING AREAS ARE APPROVED:  AREA "A" UNITS AND CORRIDORS EXCEPT AS NOTED: 133-incomplete  AREA C UNITS AND CORRIDORS APPROVED EXCEPT AS NOTED -Correct penetrations in shaft wall -147-fireblock corner of laundry ceiling line -159 not ready
---	-------------	--

Corrective Action Required:

2	SECOND FLOOR	THE FOLLOWING AREAS ARE APPROVED:  AREA "A" UNITS AND CORRIDORS AREA "B" UNITS AND CORRIDORS AREA "C" UNITS AND CORRIDORS
---	--------------	---

Corrective Action Required:

3	THIRD FLOOR	THE FOLLOWING AREAS ARE APPROVED:  AREA "A" UNITS AND CORRIDORS
---	-------------	---

AREA "B" UNITS AND CORRIDORS  
AREA "C" UNITS AND CORRIDORS

Corrective Action Required:

4            STAIR TOWER 1       STAIR TOWER "A"  
   -3RD FLOOR OK

Corrective Action Required:

5            STAIR TOWER 2       STAIR TOWER "B"  
   -3RD FLOOR OK

Corrective Action Required:

6            STAIR TOWER 3       STAIR TOWER "C"  
   -3RD FLOOR OK

**Comments:**