

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212483
Address: 2114 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Friday, August 12, 2022

Corrective Action Required:

1	Misc	-Seal exterior wall penetrations; seal above meter, AC disconnect, seal exterior lights, etc -Fix and raise the lawn irrigation box. Cannot close the lid -Provide sewer tracer wire port at grade -Middle and master bedroom smoke alarms are not interconnected with the rest of smoke alarms -Provide access to the hydro tub motor and receptacle -Close underneath boxes out wall with 5/8" GB or fire block -Secure water service pex line to wall -Locate and make accessible the sewer clean out
---	------	---

Comments: