

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220747

Address: 1980 SE BLUE PKWY, Unit:2310, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Partial	Monday, August 15, 2022

Corrective Action Required:

1	Miscellaneous Correction	-Seal penetrations at corridor wall -Lobby incomplete -Install sprinkler in back storage closet -Tie wires at light in exam room
---	-----------------------------	---

**Comments:**