

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221791
Address: 4717 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, August 15, 2022

Corrective Action Required:

1	Miscellaneous Correction	-Install windows and nail siding through out -Complete basement bath fan venting -Fire block basement half bathroom wall from ceiling -Fire block top of chase basement tub from soffit and joist space -Fire block RA space at basement plumbing vanity
---	--------------------------	--

Comments: