

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222560

Address: 451 SE OLDHAM PKWY, Unit:B, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Monday, August 15, 2022

Corrective Action Required:

1	Miscellaneous Correction	**OK TO USE NORTH PAINT BOOTH -Paint all exterior gas lines with corrosion restraint paint -Complete second booth and mixing booth
---	--------------------------	---

Comments: