

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215563
Address: 1620 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, August 15, 2022

Corrective Action Required:

1	Misc	-nail top plate to header per design portal frame -address over notched joist above single car garage for dwv -furr out and down around RA in garage for insulation -fireblock right and left of fireplace to ceiling space -address hole drilled closer than 2" to the bottom of joists above master bath -will check GB bracing at time of completion -address hole above master bath for bath fan drilled to close to edge -solid block sheathing breaks through out 2nd floor
---	------	--

Comments: