

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20210775  
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Sediment Control (ESC) Inspection</b>	Ronald Paynter	Partial	Monday, August 15, 2022

Informational:

1	Misc	No erosion issues to report on the job site today. RP 3-23-22
---	------	---

Informational:

2	Misc	Another rain day, still no erosion issues to report. RP 3-24-22
---	------	---

Corrective Action Required:

3	Misc	Curb and field inlets are full of silt and there is excess silt in the roadways. RP 4-4-22
---	------	--

Corrective Action Required:

4	Misc	Curb inlets are still full of silt. RP 4-8-22
---	------	---

Informational:

5	Misc	Curb inlets have been cleaned out. RP 4-11-22
---	------	---

Informational:

6	Misc	Welch Erosion was on site installing silt fencing. RP 4-15-22
---	------	---

Informational:

7	Misc	Need erosion control installed to prevent dirt and erosion into the yard of existing house at 2787 SW 11th Terr. Also need erosion control installed around all ADA ramp/sidewalks as mud and silt are building up and washing into roadways at these locations. 5/24/22 ES
---	------	---

Erosion control measures installed and functioning. 8/8/22 ES

Erosion control measures installed and functioning. 8/15/22 ES

**Comments:**